

NFPA 101: Life Safety Code

13.7.5.3.10

Materials within exhibit booths shall be limited to a one-day supply. Storage of materials behind the booth shall be prohibited. (See 13.7.4.2 and 13.7.5.2)

DECC Official and/or Cincinnati Fire Marshal WILL require any items be moved if/when found.